

ChE 101.04

MASS & ENERGY BALANCES PREPARATION & USE

Dr. Abdulhadi Al-Juhani

**Department of Chemical Engineering,
King Fahd University of Petroleum & Minerals**

4-12-07

Terminal Objective

Upon completion of this module, you will be able to calculate mass and energy balances and utilize these balances in evaluation of operating facilities.

Enabling Objectives

- 1. Identify data required for a mass balance and sources of losses and gains.**
- 2. Calculate mass and energy balances.**
- 3. Calculate the amount of blowdown or purge required for a recycle system.**
- 4. Identify the pieces of equipment that need to be investigated in order to debottleneck capacity.**

Using Mass and Energy Balances

Basic Equations

Mass Balance

$$\text{Mass In} = \text{Mass Out}$$

$$\text{Pounds In} = \text{Pounds Out}$$

Energy Balance

$$\text{Energy In} = \text{Energy Out}$$

$$\text{Btus In} = \text{Btus Out}$$

$$Q = mC_p\Delta t$$

$$Q = m\Delta h$$

where:

Q = heat duty, Btu/hr

m = mass rate, lbs/hr

C_p = average specific heat, Btu/lb °F

Δh = change in enthalpy, Btu/lb

Δt = change in temperature

Data Requirements

- **Data Required**
- **Data Sources**
- **Data Checking**

Figure 1 Fractionator Simulation

FRACTIONATOR OVERHEAD AND LIGHT ENDS

STREAM ID.	1	2	3	4	5	6	7
STREAM NAME.....	OVERHEAD	SOUR WATER	REFLUX	DISTILLATE	DISTILLATE	1ST STAGE	1ST STAGE
.....	FROM	FROM	TO	LIQUID FROM	VAPOR FROM	COMPRESSOR	INTERCOOLER
.....	FRACTIONATOR	REFLUX DRUM	FRACTIONATOR	REFLUX DRUM	REFLUX DRUM	DISCHARGE	FEED
*** WET BASIS ***							
*** TOTAL STREAM ***							
TEMPERATURE, DEG F	243.8699	109.9998	110.0000	110.0000	110.0000	239.9617	160.6182
PRESSURE, PSIA	20.3000	16.7000	16.7000	16.7000	16.7000	54.0574	54.1000
MOLE FRAC LIQUID....	0.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.5243
ENTHALPY M*BTU /HR	447.0229	10.9994	2.7255	0.3162	44.6961	58.4291	69.4287
RATE LB MOL/HR	24522.9375	7830.7969	6492.9961	753.2190	6925.2422	6925.2422	14756.0352
RATE LB /HR	1204360.0000	141071.7500	708331.6250	82169.6250	227375.8120	227375.8120	368447.4370
STD.RATE K* FT3/DAY	223348.94	71320.94	59136.63	6860.13	63073.42	63073.42	134394.25
STD. LV RATE BBL/DAY	116019.44	9683.70	63529.66	7369.75	32319.30	32319.30	42002.98
MOLECULAR WEIGHT....	49.1116	18.0150	109.0916	109.0913	32.8329	32.8329	24.9693
AVG. BP (MOLE) F	129.2372	211.9997	243.9437	243.9434	-114.4970	-114.4970	58.7701
CRIT. TEMP., F	495.5847	705.5603	571.4163	571.4158	102.3762	102.3762	422.4744
CRIT. PRES, PSIA	1712.4731	3208.1313	452.6282	452.6282	795.0657	795.0657	2075.6382
UOP K (MOLE BASIS)..	12.7069	8.7615	11.7716	11.7716	19.5829	19.5829	13.8402
*** VAPOR PHASE ***							
RATE LB MOL/HR	24522.9375	0.0000	0.0000	0.0000	6925.2422	6925.2422	7020.0156
RATE LB /HR	1204360.0000	0.0000	0.0000	0.0000	227375.8120	227375.8120	229082.9370
ACT.RATE FT3/SEC	2505.77	0.00	0.00	0.00	699.06	264.00	235.68
ACT.DENS LB /FT3	0.1335	0.0000	0.0000	0.0000	0.0904	0.2392	0.2700
COMPRESSIBILITY (Z).	0.9891	0.0000	0.0000	0.0000	0.9927	0.9881	0.9823
VISCOSITY, CP	0.0108	0.0000	0.0000	0.0000	0.0103	0.0125	0.0112
CP, BTU /LB F	0.4641	0.0000	0.0000	0.0000	0.4428	0.5088	0.4724
CP/(CP-R) RATIO.....	1.0955	0.0000	0.0000	0.0000	1.1583	1.1350	1.1480
*** LIQUID PHASE ***							
RATE LB MOL/HR	0.0000	7830.7969	6492.9961	753.2190	0.0000	0.0000	7736.0117
RATE LB /HR	0.0000	141071.7500	708331.6250	82169.6250	0.0000	0.0000	139364.1870
ACT.RATE GAL/MIN	0.00	284.35	1908.03	221.34	0.00	0.00	284.89
STD.DENS(LV) LB /GAL	0.0000	8.3245	6.3712	6.3712	0.0000	0.0000	8.3245
ACT.DENS LB /GAL	0.0000	8.2687	6.1873	6.1872	0.0000	0.0000	8.1531
ACT.DENS LB /FT3	0.0000	61.8537	46.2839	46.2837	0.0000	0.0000	60.9895
VISCOSITY, CP	0.0000	0.6120	0.4019	0.4019	0.0000	0.0000	0.3926
CP, BTU /LB F	0.0000	0.9976	0.4924	0.4924	0.0000	0.0000	1.0007
REID VAPOR PRES.PSIG	0.0000	14.1081	6.8816	6.8817	0.0000	0.0000	14.1081

Exercise 1.1

Directions:

Check the data on the attached sketch and the table below. Which data appear incorrect? How would these be checked?

Plant Data

C1 Reflux	FC-1	13,450B/D
C1 Rblr Stm	FC-2	44,500 lb/hr
C2 Reflux	FC-3	29,454 B/SD
Sour C4 Prod	FC-4	19,270 B/SD
C2 Rblr Stm	FC-5	20,600 lb/hr
Feed	NGL	19,000 lb/hr
Feed	LPG	499,560 lb/hr

150 psig Steam Enthalpy Dam

$$H_V = 1194.10 \text{ Btu/lb}$$

$$H_L = 330.65 \text{ Btu/lb}$$




Figure 5 PFD Debutanizer and Depropanizer

Exercise 1.1, Cont'd

Item No. 1: Check the overall mass balance.

Inlet feed LPG : 499.56×10^3 lb/hr

Inlet NGL : 19.0×10^3 lb/hr

Propane out : $31.46 \times 10^3 \times 42 \times \frac{0.51 \times 8.33 \text{ lb}}{24} = 233.89 \times 10^3$ lb/hr

Butane out : $19.27 \times 10^3 \times 42 \times \frac{0.58 \times 8.33 \text{ lb}}{24} = 162.93 \times 10^3$ lb/hr

Debutanizer

Bottoms : $(11.89 + 1.2) \times 10^3 \times 42 \times \frac{0.64 \times 8.33 \text{ lb}}{24} = 122.12 \times 10^3$ lb/hr

	In		Out
LPG	499.56	Propane	233.89
NGL	19.00	Butane	162.93
	518.56	Bottoms	122.12
			518.94

Exercise 1.1, Cont'd

Item No. 2: Check the C-1 reflux rate.

Pump G-1 rate:

sp.gr. at 60°F = 0.51 from PFD

sp.gr. at 130°F = 0.44 Maxwell, Pg. 140 (for propane)

$$2761 \frac{\text{gal}}{\text{min}} \times \frac{0.44 \times 8.33 \text{ lb}}{\text{gal}} \times \frac{60 \text{ min}}{\text{hr}} = 607.18 \times 10^3 \text{ lb/hr}$$

Propane product rate = 233.89 x 10³ lb/hr

Reflux = 607.18 – 233.89 = 373.29 x 10³ lb/hr

$$= 373.29 \times 10^3 \frac{\text{lb}}{\text{hr}} \times \frac{\text{gal}}{0.51 \times 8.33 \text{ lb}} \times \frac{24 \text{ hr}}{\text{D}} \times \frac{\text{B}}{42 \text{ gal}} = 50,210 \text{ B/D @ 60°F}$$

Reflux per FC-1 = 13,450 B/D

Exercise 1.1, Cont'd

Item No. 3: Check the C-2 reflux rate.

Pump G-2 rate:

$$\text{sp.gr. at } 60^{\circ}\text{F} = 0.58$$

$$\text{sp.gr. at } 150^{\circ}\text{F} = 0.524 \text{ Maxwell, Pg. 140}$$

(Note : check if 60°F point falls on N-C₄ curve.)

$$1573 \frac{\text{gal}}{\text{min}} \times 0.524 \times 8.33 \times \frac{\text{lb}}{\text{gal}} \times \frac{60 \text{ min}}{\text{hr}} = 411.96 \times 10^3 \text{ lb/hr}$$

$$\text{Butane rate} = 162.93 \times 10^3 \text{ lb/hr}$$

$$\text{Reflux} = 411.96 - 162.93 = 249.03 \times 10^3 \text{ lb/hr}$$

$$= 249.03 \times 10^3 \frac{\text{lb}}{\text{hr}} \times \frac{\text{gal}}{0.58 \times 8.33 \text{ lb}} \times \frac{\text{B}}{42 \text{ gal}} \times \frac{24 \text{ hr}}{\text{D}} = 29,454 \frac{\text{B}}{\text{D}}$$

$$\text{Reflux per FC-3} = 29,454 \text{ B/D}$$

Exercise 1.1, Cont'd

Item No. 4: Check the C-2 bottoms rate.

sp.gr. at 60°F = 0.64

sp.gr. at 120°F = 0.61 Maxwell, Pg. 140

Note : 60°F point falls just above the C₅ curve.

Maintaining the same distance, read 0.61 at 120°F.

Pump G-3/44 rate:

$$\begin{aligned} (370+35) \frac{\text{gal}}{\text{min}} \times 0.61 \times 8.33 \times \frac{\text{lb}}{\text{gal}} \times \frac{60 \text{ min}}{\text{hr}} &= 12347 \times 10^3 \text{ lb/hr} \\ &= 12347 \times 10^3 \times \frac{\text{gal}}{0.64 \times 8.33 \text{ lb}} \times \frac{24}{42} \end{aligned}$$

$$= 13,235 \text{ B/D}$$

$$\text{PFD rate} = 11,890 + 1,200 = 13,090 \text{ B/D}$$

Exercise 1.1, Cont'd

Item No. 5: Check reboiler heat inputs.

<u>Exchanger</u>	<u>PFD Q, Btu/hr</u>	<u>Steam rate, lb/hr</u>
E-2	44.5×10^6	44,500
E-5	20.6×10^6	20,600

$$\begin{aligned} H_V \text{ steam} &= 1194.1 \text{ Btu/lb} \\ H_L &= \underline{330.65} \\ \text{Net Q, Btu/lb} &= 863.45 \end{aligned}$$

$$Q_{E2} = 44,500 \frac{\text{lb}}{\text{hr}} \times 863.45 \text{ Btu/lb} = 38.4 \times 10^6$$

Btu/hr

$$Q_{E5} = 20,600 \times 863.45 = 17.8 \times 10^6 \text{ Btu/hr}$$

Exercise 1.1, Cont'd

1. Overall Mass Balance – OK (Check Gas to Fuel)
2. FC-1 13, 450 B/D, Pump 50, 210 B/D – Field Check Required
3. FC-3 & Pump Check – OK
4. PFD & Pump Check – OK
5. PFD & Calc Q – Calc Q Lower – Field Check

Mass Balance Preparation

- **Define Data Required**
 - **New Unit**
 - **Revised Unit**
 - **Operating unit**

- **Correcting Meter Readings**

Balances Around an Operating Unit

New

- **Product Specifications Govern**
- **Designer Responsible for Economical Process Design**

Changed

- **Equipment Configuration Established**
- **Run Programs**
 - **Distillation**
 - **Heat Exchanger**
- **Determine Equipment Limitations**

Balances Around an Operating Unit

- Determine How Unit is Operating
- Determine What is Being Produced
- Analysis Made on Fuels and
- Calculate Heat Duties, etc.
- Check Data for Consistency and Reasonableness
- Determine Scope of the Balance

Correcting Meter Readings

- Ensure Meter Factors Are Accurate for Test
- Constants Include All Variables
- For Liquids

$$Q_{\text{vol/time}} = \text{Constant } t \sqrt{\frac{\text{sp.gr.cond.}}{\text{sp.gr.at 60}}} \sqrt{\Delta P}$$

$$W_{\text{weight/time}} = \text{Constant } t \sqrt{\text{sp.gr.cond.}} \sqrt{\Delta P}$$

- For Gas

$$W_{\text{weight/time}} = \text{Constant } t \sqrt{\frac{(\text{MW})(P)}{10.73 T_F Z_F}} \sqrt{\Delta P}$$

Liquid or Gases

- Given Changes to Original Calculations, then
- For Liquids

$$\text{Actual vol/time} = \text{Flow reading} \times \sqrt{\frac{\rho_A}{\rho_{AM}}} \times \frac{\rho_{60M}}{\rho_{60A}}$$

$$\text{Actual weight/time} = \text{Flow reading} \times \sqrt{\frac{\rho_A}{\rho_{AM}}}$$

- For Gases

$$\text{Vapor density} = \rho = \frac{\text{MW } P}{10.73 \text{ T } Z}$$

Example Problem 1

LABORATORY ANALYSIS DATA


	<u>Feed</u> <u>Mole%</u>	<u>C₃ LPG</u> <u>Mole %</u>	<u>C₄ LPG.</u> <u>Mole %</u>
MW	50.92	42.8	57.8
API	121	143	108.5
MoABP	-8.87	-50.4	22.1
K	12+	12+	12+
Sp. Gr.	0.5604	0.5155	0.5896

Example Problem 1, Cont'd

PLANT DATA

Feed	FIC 1	8,237 B/D
Reflux	FIC-2	8,296
C ₃ OH Prod.	FIC-3	3,158
C ₄ Bottom Prod.	FIC-4	4,920
PA	FIC-5	73,050
Feed	TW-1	100°F
C ₄ Bottom Prod.	TI-9	100°F
Reflux	TI-12	107.7°F
C ₃ OH Prod.	TI-13	100°F
Tower OH	PIC-1	220 psig
P ₁ Disch. (C ₃ OH Prod.)	PI 3	357 psig

Figure 2 C3/C4 Splitter



Example Problem 1, Cont'd

	FIC-1	FIC-3	FIC-4
Instrument Records			
Sp.Gr. ₆₀	0.550	0.515	0.589
SP.GR. _{fluid}	0.509	0.456	0.538
 Laboratory APIa			
Sp. Gr. ₆₀	0.561	0.515	0.589
Temp	100°F	100°F	100°F
Sp.Gr. _{fluid}	0.530	0.479	0.565

$$V_{\text{actual}} = V_{\text{reading}} \times$$

$$\sqrt{\frac{\text{sp. gr.}_A}{\text{sp. gr.}_{AM}}} \times \frac{\text{sp. gr.}_{60M}}{\text{sp. gr.}_{60A}}$$

Example Problem 1, Cont'd

$$\text{FIC-1} = 8237 \times \sqrt{\frac{0.530}{0.509}} \times \frac{0.55}{0.561} = 8279 \text{ B/SD}$$

$$\text{FIC-3} = 3158 \times \sqrt{\frac{0.479}{0.456}} \times \frac{0.515}{0.515} = 3237 \text{ B/D}$$

$$\text{FIC-4} = 4920 \times \sqrt{\frac{0.565}{0.538}} \times \frac{0.589}{0.589} = 5042 \text{ B/D}$$

Example Problem 1, Cont'd

Overall balance:

		<u>B/D</u>	<u>lbs/hr</u>
Feed =	8279 B/D	Products 3237	24,301
	67,705 lbs/hr	<u>5042</u>	<u>43,304</u>
		8279	67,665 (0.06%)

Note the results if uncorrected:

		<u>B/D</u>	<u>lbs/hr</u>
Feed =	8237	Products 3158	23,708
	= 67,361 lbs/hr	<u>4920</u>	<u>42,256</u>
		8078	65,964 (2.07%)

Exercise 1.2

Directions:

Using the following Process Flow Diagram, discuss with the instructor what plant data are required to prepare a mass balance around the unit. Assume pressure and temperature measurements can be made where required.

Answer:

Lead a discussion on the data required.

Liquid flows require gravity and temperature of fluid to correct meters.

Vapor (gas) flows require molecular weight or specific gravity, temperature and pressure of fluid to correct meters.




Figure 6 PFD CDU's 1 & 2

Exercise 2

Answer:

Check the overall balance:

		<u>B/D</u>	<u>lbs/Hr</u>
FIC-1	8,279 B/D	FIC-3 3237	24,301
	67,705lbs/hr	FIC-4 <u>5042</u>	<u>43,304</u>
		8279	67,665

Write these values on the sketch.

Exercise 2, Cont'd

Answer

		<u>sp. gr.</u>
2.	Feed API from analysis = 121	.5604
	C ₃ LPG = 143	.5155
	C ₄ LPG = 108.5	.5896

Write these values on the sketch.

Exercise 2, Cont'd

Pump rates - C₃ LPG

60°F 143°API = 0.516 Sp.Gr. (LPG)

Temperature = 107.7°F

Maxwell, Pg. 140 propane @ 108°F = 0.462 sp.gr.

Maxwell, Pg. 2 propane @ 60°F = 0.508 sp.gr.

$$\text{P-1 rate} = 3237 \times \frac{D}{24 \text{ hr}} \times \frac{\text{hr}}{60 \text{ min}} \times \frac{42 \text{ gal}}{\text{bbl}} \times \frac{0.508 \text{ Sp.Gr. at } 60^\circ \text{ F}}{0.462 \text{ Sp.Gr. at cond.}} = 103.8 \text{ gpm}$$

$$\text{P-2 rate} = \frac{8296}{3237} \times 103.8 = 266.0 \text{ gpm}$$

Exercise 2, Cont'd

E-4 C₃ product cooler

Stream data : 3237 B/D, 143°API, 42.8 MW, -50.4 MoABP, K = 12 +

At 60°F 143°API = 0.516 Sp.Gr.

$$\text{Rate} = 3237 \times \frac{\text{B}}{\text{D}} \times \frac{42}{24} \times 0.516 \times 8.33 = 24,349$$

lb/hr

Temperature	=	TI-12	TI-13
		107.7°F	100°F

Heat capacity:	107.7°F	100°F	
Propane H, Btu/lb	176	170	(Maxwell, Pg. 100)

(Cannot use the API chart, since it is beyond the range for C_p on Maxwell, Pg. 93.)

$$Q = (176-170) \times \frac{\text{Btu}}{\text{lb}} \times 24,349 \frac{\text{lb}}{\text{hr}} = 0.146 \times 10^6$$

Btu/hr

Exercise 2, Cont'd

E-2 Reboiler – Use the heating media side

Temperature 324.8 in 301.2 out

Data 73,050 B/D, 38.6°API, 347.4 MoABP

Sp.Gr. at 60°F = 0.831

$$\text{Rate} = 73,050 \times \frac{42}{24} \times 0.831 \times 8.33 = 884,920 \text{ lb/hr}$$

Heat capacity :

	<u>Temperature</u>	<u>325°F</u>	<u>301°F</u>
$C_p + B =$		0.635	0.620
B		<u>-0.052</u>	<u>-0.052</u>
C_p		0.583	0.568
			Ave. = 0.575

$$Q = 884,920 \times 0.575 \times (325-301) = 12.2 \times 10^6 \text{ Btu/hr}$$

Exercise 2, Cont'd

E-5 C₄ product cooler.

Rate is same as E-1 = 43,365 lb/hr

<u>Temperature</u>	<u>123°F</u>	<u>100°F</u>
C _p + B =	0.75	0.735
B	<u>-0.17</u>	<u>-0.17</u>
C _p	0.58	0.565 Ave. = 0.572

$$Q = 43,365 \times 0.572 \times (123-100) = 0.57 \times 10^6 \text{ Btu/hr}$$