

Evaluating the voltage stability of a power system via transmission paths determination is presented in this paper. Both active and reactive transmission paths are investigated. The worst path is validated through the evaluation of the voltage stability level at each bus. Both methods are found to be consistent and efficient for voltage stability evaluation. Results of test conducted on six bus system and the IEEE 30 bus are presented and discussed.