


SOLUTIONS TO CHAPTER 8

8.1



$$I_h = \frac{100 \times 10^3}{11 \text{ kV}} = 9.1 \text{ Amperes}$$

use CTR = 10:5 (2/1)

$$I_1 = \frac{100 \times 10^3}{3.3 \text{ kV}} = 30.3 \text{ Amperes}$$

use CTR = 40:5 (8/1)

$$\text{Fault @ Bus C} = \frac{1.0}{.1 + j.8} = 1.2 \text{ pu}$$

$$\text{Max load} = 1.25 \times I_{f1} = 37.88 \text{ A}$$

R_{bc} must be set above max. load but at this setting it cannot see faults at Bus C

$$\text{Fault @ Bus B} = \frac{1.0}{0.2} = 5.0 \text{ pu. } R_{bc} \text{ can protect for close-in faults.}$$


$$\text{Set } R_{bc} \text{ at } \frac{1.25 \times 30.3}{8} = 4.7 \text{ Amperes --- Set on 4.8 tap; T.D} = \#1/2$$

For fault at Bus B, R_{bc} has $\frac{5 \times 30.3}{8 \times 4.8} = 3.95 \times \text{pu}$ and operates in 0.50 seconds. Add 0.3 seconds coordinating time = 0.80 seconds.

$$\text{Set } R_{ab} \text{ at } \frac{1.2 \times 9.1}{2} = 5.7 \text{ amperes --- Set on 6.0 tap.}$$

For fault at Bus B, R_{ab} has $\frac{5 \times 9.1}{6 \times 2} = 3.8 \times \text{pu}$. To operate in 0.67 seconds set on T.D. = #1

8.2



$$\text{Max. load} = 120\% \times 50 = 60 \text{ MV}$$

$$\text{LTC} = +10\% \text{ CT error} = 5\%$$

$$I_h = \frac{60 \times 10^6}{110 \times 10^3} = 545.45 \text{ Amperes}$$

use CTR = 600:5 (120/1)

$$I_{hsec} = 4.545 \text{ Amperes Tap} = 4.8$$

$$I_1 = \frac{60 \times 10^6}{33 \times 10^3} = 1818.18 \text{ Amperes}$$

use CTR = 2000:5 (400/1)
 $I_{sec} = 4.545$ Amperes Tap = 4.3
 CT mismatch = 0


Error due to LTC = 10%
 Error due to CT = 5%
 Safety margin = 5%

slope = 20% Use lowest pickup tap
 provided on specific relay.

8.3

Yes. With no tapchanger the slope could be 10%.

8.4



Single Phase Transformer
 Percentage Differential relay
 slope = 20% and minimum pickup
 = 0.25 Amperes

Max. overload = 110% × 10
 = 11 MVA

$$I_h = \frac{11 \times 10^6}{69 \times 10^3} = 159.42 \text{ Amperes}$$

use CTR = 200:5 (40/1)

$$I_{hsec} = 3.98$$

$$I_1 = \frac{11 \times 10^6}{33 \times 10^3} = 333.33 \text{ Amperes}$$

use CTR = 400:5 (80/1)
 $I_{sec} = 4.17$

At No-load- $I_{restr} = 0 - I_{diff} = \frac{I_f}{40} > 0.25$ - So $I_f > 10$ Amperes pri.

$$\text{At Max overload- } I_{restr} = \frac{1}{2} \times \left(\frac{159.42}{40} + \frac{333.33}{80} \right) = 4.08$$

$$I_{diff} = 0.2 \times I_{restr} = 0.816 \text{ Amperes to operate.}$$

For Internal Fault, assuming no source on the 33 kV side,
 $I_f = 0.816 \times 40 = 32.64$ Amperes primary.

At No-load the percentage winding protected is

$$\left(1 - \frac{10}{159.4} \right) \times 100\% = 93.7\%$$

At Max. overload the percentage winding protected

$$\left(1 - \frac{32.64}{159.4} \right) \times 100\% = 79.5\%$$