KING FAHD UNIVERSITY OF PETROLEUM & MINERALS COLLEGE OF COMPUTER SCIENCES & ENGINEERING

Department of Systems Engineering



SE 401

COMPUTER CONTROL SYSTEMS LAB MANUAL

Systems Engineering Department SE 401 COMPUTER CONTROL SYSTEMS

Laboratory Objective

Emphasize the practical aspects of the course and enable each student to:

- Simulate systems described using
 - o LabVIEW
- Be familiar with equipment needed such as two tank model, function generator, oscilloscope, etc...

To understand, simulate and observe behavior of first and second order systems.

TABLE OF CONTENTS

EXPERIMENT # 1: INTRODUCTION TO LABVIEW	
EXPERIMENT # 2: BUILDING A VI	8
EXPERIMENT # 3: EXERCISES IN LABVIEW	
EXPERIMENT # 4: DATA ACQUISITION	
EXPERIMENT # 5: SENDING AN ANALOG OUTPUT	
EXPERIMENT # 6: DIGITAL INPUT / OUTPUT	
EXPERIMENT # 7: ON-OFF CONTROL	
EXPERIMENT # 8: ON-OFF CONTROL WITH DEAD ZONE	40
EXPERIMENT # 9: PROPOTIONAL CONTROL	44
EXPERIMENT # 10: PI CONTROLLER	47

EXPERIMENT # 1: INTRODUCTION TO LABVIEW

OBJECTIVE:

The objective of this experiment is the introduction of LabView.

INTRODUCTION:

LabVIEW (short for **Lab**oratory Virtual Instrumentation Engineering Workbench) is a platform and development environment for a visual programming language from National Instruments. The graphical language is named "G". LabVIEW is commonly used for data acquisition, instrument control, and industrial automation on a variety of platforms including Microsoft Windows, various flavors of UNIX, Linux, and Mac OS.

One benefit of LabVIEW over other development environments is the extensive support for accessing instrumentation hardware. Drivers and abstraction layers for many different types of instruments and buses are included or are available for inclusion. These present themselves as graphical nodes. The abstraction layers offer standard software interfaces to communicate with hardware devices. The provided driver interfaces save program development time. Many libraries with a large number of functions for data acquisition, signal generation, mathematics, statistics, signal conditioning, analysis, etc., along with numerous graphical interface elements are provided in several LabVIEW package options. Another benefit of the LabVIEW environment is the platform independent nature of the *G*-code (LabVIEW programming language), which is (with the exception of a few platform-specific functions) portable between the different LabVIEW systems for different operating systems (Windows, MacOSX and Linux).

DATAFLOW:

The programming language used in LabVIEW, called "G", is a dataflow language. Execution is determined by the structure of a graphical block diagram (the LV-source code) on which the programmer connects different function-nodes by drawing wires. These wires propagate variables and any node can execute as soon as all its input data become available. Since this might be the case for multiple nodes simultaneously, G is inherently capable of parallel execution.

The afore-mentioned data-flow (which can be "forced", typically by linking inputs and outputs of nodes) completely defines the execution sequence, and that can be fully controlled by the programmer. Thus, the execution sequence of the LabVIEW graphical syntax is as well-defined as with any textually coded language such as C, Visual BASIC, etc. Furthermore, LabVIEW does not require type definition of the variables; the wire type is defined by the data-supplying node. LabVIEW supports polymorphism in that wires automatically adjust to various types of data.



Screenshot of a simple LabVIEW program that generates, synthesizes, analyzes and displays waveforms, showing the block diagram and front panel. Each symbol on the block diagram represents a LabVIEW subroutine (subVI) which can be another LabVIEW program or a LV library function.

GRAPHICAL PROGRAMMING:

LabVIEW ties the creation of user interfaces (called front panels) into the development cycle. LabVIEW programs/subroutines are called virtual instruments (VIs). Each VI has three components: Each VI contains three main parts:

- 1. Front Panel How the user interacts with the VI.
- 2. Block Diagram The code that controls the program.
- 3. Icon/Connector Means of connecting a VI to other VIs.

The **Front Panel** is the user interface of the VI, to interact with the user when the program is running. Users can control the program, change inputs, and see data updated in real time. You build the front panel with controls and indicators (available on the **Control Palette**), which are the interactive input and output terminals of the VI, respectively. Controls are knobs, pushbuttons, dials, and other input devices. Indicators are graphs, LEDs, and other displays.

Controls simulate instrument input devices and supply values to the block diagram of the VI. Indicators simulate instrument output devices and display values the block diagram acquires or generates. These may include data, program states, and other information. Every front panel control or indicator has a corresponding terminal on the block diagram. When a VI is run, values from controls flow through the block diagram, where they are

used in the functions on the diagram, and the results are passed into other functions or indicators.



The Controls palette is available only on the front panel. Go to Window»Show Controls Palette or right-click the front panel workspace to display the Controls palette.

The **Block Diagram** contains this graphical source code. Front panel objects appear as terminals on the block diagram. Additionally, the block diagram contains functions and structures from built-in LabVIEW VI libraries. These can be accessed from the **Functions Palette**. Wires connect each of the nodes on the block diagram, including control and indicator terminals, functions, and structures.

The **Functions** palette is available only on the block diagram. Select **Window»Show Functions Palette** or right-click the block diagram workspace to display the **Functions** palette



The **Icon/Connector** may represent the VI as a subVI in block diagrams of calling VIs. Controls and indicators on the front panel allow an operator to input data into or extract data from a running virtual instrument. However, the front panel can also serve as a programmatic interface. Thus a virtual instrument can either be run as a program, with the front panel serving as a user interface, or, when dropped as a node onto the block diagram, the front panel defines the inputs and outputs for the given node through the connector pane. This implies each VI can be easily tested before being embedded as a subroutine into a larger program.

The graphical approach also allows non-programmers to build programs by simply dragging and dropping virtual representations of the lab equipment with which they are already familiar. The LabVIEW programming environment, with the included examples and the documentation, makes it easy to create small applications. For complex

algorithms or large-scale code it is important that the programmer possess an extensive knowledge of the special LabVIEW syntax and the topology of its memory management. The most advanced LabVIEW development systems offer the possibility of building stand-alone applications.

Other features that you will need include the **Tools Palette** which is a Floating Palette that is used to operate and modify front panel and block diagram objects and the **Status Toolbar**. They contain the following tools and buttons, respectively:

Tools Palette:

陸 т 🔀	* =	Automatic Selection Tool
	🔊 Operating Tool	ংশি Scrolling Tool
� ┡ Aĭ ≫ ष= @	✤ Positioning/Res	izing Tool 🛛 🖲 Breakpoint Tool
	A Labeling Tool	+®- Probe Tool
	✤ Wiring Tool	🖉 Color Copy Tool
└─┚╺╱	t≊ Shortcut Menu 1	۲ool 🛛 🖣 🖌 Coloring Tool
Status Bar:	💡 🏎 🗃 🔐 13pt	Application Font
♦ 🖬	Run Button	Execution Highlighting Button
	Continuous Run Button	Step Into Button
	Abort Execution	🖻 Step Over Button
	Pause/Continue Button	Step Out Button
	Γext Settings Align Objects	
	Distribute Objects	
	Reorder	
	Resize front panel objects	

EXPERIMENT # 2: BUILDING A VI

OBJECTIVE:

The objective of this experiment is to build a VI.

INTRODUCTION:

Before building our own VI we will first examine the **Signal Generation and Processing** VI and run it. Change the frequencies and types of the input signals and notice how the display on the graph changes. Change the Signal Processing Window and Filter options. After you have examined the VI and the different options you can change, stop the VI by pressing the Stop button.

1. Select **Start»Programs»National Instruments»LabVIEW 8.0 » LabVIEW** to launch LabVIEW. The **LabVIEW** dialog box appears.

2. Select **Help»Find Examples.** The dialog box that appears lists and links to all available LabVIEW example VIs.

3. On the Browse Tab, select browse according to task. Choose **Analyzing and Processing Signals**, then **Signal Processing**, then **Signal Generation and Processing.vi.** This will open the Signal Generation and Processing VI Front Panel.

Note You also can open the VI by clicking the **Open VI** button and navigating to labview\examples\apps\demos.llb\Signal Generation and Processing.vi.

FRONT PANEL

4. Click the **Run** button on the toolbar, shown at left, to run this VI. This VI determines the result of filtering and windowing a generated signal. This example also displays the power spectrum for the generated signal. The resulting signals are displayed in the graphs on the front panel, as shown in the following figure.

5. Use the Operating tool, shown at left, to change the Input Signal and the Signal Processing, use the increment or decrement arrows on the control, and drag the pointer to the desired Frequency.

6. Press the More Info... button or [F5] to read more about the analysis functions.

7. Press the **Stop** button or [F4] to stop the VI.



BLOCK DIAGRAM

8. Select **Window**»**Show Diagram** or press the <Ctrl-E> keys to display the block diagram for the Signal Generation and Processing VI.

This block diagram contains several of the basic block diagram elements, including subVIs, functions, and structures, which you will learn about later in this course.

9. Select **Window**»**Show Panel** or press the <Ctrl-E> keys to return to the Front Panel.

10. Close the VI and do not save changes.

CREATING YOUR OWN VI

When you create an object on the Front Panel, a terminal will be created on the Block Diagram. These terminals give you access to the Front Panel objects from the Block Diagram code. Each terminal contains useful information about the Front Panel object it corresponds to. For example, the color and symbols provide the data type. Double-precision, floating point numbers are represented with orange terminals and the letters DBL, boolean terminals are green with TF lettering. In general, orange terminals should wire to orange terminals, green to green, and so on. This is not a hard-and-fast rule; LabVIEW will allow a user to connect a blue terminal (integer value) to an orange terminal (fractional value), for example.

For more help with the terminals, right-click on the function and select **Visible Items»Terminals**. The functions picture will be pulled back to reveal the connection terminals. For additional help, select **Help**»**Show Context Hel**p, or press <Ctrl-H>. As you move your mouse over the function, this window will show you the function, terminals, and a brief help description in the context help window. For organization you can, right-click on the particular wire in question and choose **Clean Up Wire** to automatically re-route that wire.



VI # 1- Convert °C to °F

Complete the following steps to create a VI that takes a number representing degrees Celsius and converts it to a number representing degrees Fahrenheit.

In wiring illustrations, the arrow at the end of this mouse icon shows where to click and the number on the arrow indicates how many times to click.

Front Panel

- 1. Select **File**»**New** to open a new front panel.
- 2. (Optional) Select **Window»Tile Left and Right** to display the front panel and block diagram side by side.
- 3. Create a numeric digital control. You will use this control to enter the value for degrees Centigrade.
 - a. Select the digital control on the **Controls**»**Numeric Controls** palette. If the **Controls** palette is not visible, right-click an open area on the front panel to display it.
 - b. Move the control to the front panel and click to place the control.
 - c. Type deg C inside the label and click outside the label or click the **Enter** button on the toolbar. If you do not type the name immediately, LabVIEW uses a default label. You can edit a label at any time by using the Labeling tool.
- 4. Create a numeric digital indicator. You will use this indicator to display the value for degrees Fahrenheit.
 - a. Select the digital indicator on the **Controls**»Numeric Indicators palette.
 - b. Move the indicator to the front panel and click to place the indicator.
 - c. Type deg F inside the label and click outside the label or click the **Enter** button.

LabVIEW creates corresponding control and indicator terminals on the block diagram. The terminals represent the data type of the control or indicator. For example, a DBL terminal represents a double-precision, floating-point numeric control or indicator.

Note Control terminals have a thicker border than indicator terminals.

Block Diagram

5. Display the block diagram by clicking it or by selecting **Window**»Show **Diagram**.



Note: Block Diagram terminals can be viewed as icons or as terminals. To change the way LabVIEW displays these objects right click on a terminal and select **View As Icon**.



- 6. Select the Multiply and Add functions on the **Functions**»**Numeric** palette and place them on the block diagram. If the **Functions** palette is not visible, right-click an open area on the block diagram to display it.
- 7. Select the numeric constant on the **Functions**»**Numeric** palette and place two of them on the block diagram. When you first place the numeric constant, it is highlighted so you can type a value.
- 8. Type 1.8 in one constant and 32.0 in the other. If you moved the constants before you typed a value, use the Labeling tool to enter the values.
- 9. Use the Wiring tool to wire the icons as shown in the previous block diagram.
 - To wire from one terminal to another, use the Wiring tool to click the first terminal, move the tool to the second terminal, and click the second terminal, as shown in the following illustration. You can start wiring at either terminal.



- You can bend a wire by clicking to tack the wire down and moving the cursor in a perpendicular direction. Press the spacebar to toggle the wire direction.
- To identify terminals on the nodes, right-click the Multiply and Add functions and select **Visible Items»Terminals** from the shortcut menu to display the connector pane. Return to the icons after wiring by right-clicking the functions and selecting **Visible Items»**
- **Terminals** from the shortcut menu to remove the checkmark.
- When you move the Wiring tool over a terminal, the terminal area blinks, indicating that clicking will connect the wire to that terminal and a tip strip appears, listing the name of the terminal.
- To cancel a wire you started, press the <Esc> key, right-click, or click the source terminal.

10. Display the front panel by clicking it or by selecting **Window**»Show Panel.

11. Save the VI for later use (have a folder by your own name).

- 12. Enter a number in the digital control and run the VI.
 - a. Use the Operating tool or the Labeling tool to double-click the digital control and type a new number.
 - b. Click the **Run** button to run the VI.
 - c. Try several different numbers and run the VI again.

VI # 2 – Create a SubVI

Front Panel

1. Select **File**»**Open** and navigate to your folder to open the C to F VI. The following front panel appears.



- 2. Right-click the icon in the upper right corner of the front panel and select **Edit Icon** from the shortcut menu. The **Icon Editor** dialog box appears.
- 3. Double-click the Select tool on the left side of the **Icon Editor** dialog box to select the default icon.
- 4. Press the <Delete> key to remove the default icon.
- 5. Double-click the Rectangle tool to redraw the border.
- 6. Create the following icon.



- a. Use the Text tool to click the editing area.
- b. Type C and F.
- c. Double-click the Text tool and change the font to Small Fonts.
- d. Use the Pencil tool to create the arrow. (To draw horizontal or vertical straight lines, press the *<*Shift> key while you use the Pencil tool to drag the cursor).
- e. Use the Select tool and the arrow keys to move the text and arrow you created.
- f. Select the **B&W** icon and select **256** Colors in the Copy from field to create a black and white icon, which LabVIEW uses for printing unless you have a color printer.
- g. When the icon is complete, click the **OK** button to close the **Icon Editor** dialog box. The icon appears in the upper right corner of the front panel and block diagram.
- 7. Right-click the icon on the front panel and select **Show Connector** from the shortcut menu to define the connector pane terminal pattern.

LabVIEW selects a connector pane pattern based on the number of controls and indicators on the front panel. For example, this front panel has two terminals, **deg C** and **deg F**, so LabVIEW selects a connector pane pattern with two terminals.

- 8. Assign the terminals to the digital control and digital indicator.
 - a. Select **Help**»**Show Context Help** to display the **Context Help** window. View each connection in the **Context Help** window as you make it.
 - b. Click the left terminal in the connector pane. The tool automatically changes to the Wiring tool, and the terminal turns black.
 - c. Click the **deg C** control. The left terminal turns orange, and a marquee highlights the control.
 - d. Click an open area of the front panel. The marquee disappears, and the terminal changes to the data type color of the control to indicate that you connected the terminal.

- e. Click the right terminal in the connector pane and click the $\deg F$ indicator. The right terminal turns orange.
- f. Click an open area on the front panel. Both terminals are orange.
- g. Move the cursor over the connector pane. The **Context Help** window shows that both terminals are connected to floating-point values.
- 9. Select File»Save to save the VI.

VI # 3 – Using Loops

Use a while loop and a waveform chart to build a VI that demonstrates software timing.

Front Panel

- 1. Open a new VI.
- 2. Build the following front panel.



- a. Select the horizontal pointer slide on the **Controls**»**Numeric Controls** palette and place it on the front panel. You will use the slide to change the software timing.
- b. Type millisecond delay inside the label and click outside the label or click the **Enter** button on the toolbar, shown at left.
- c. Place a Stop Button from the Controls»Buttons palette.
- d. Select a waveform chart on the **Controls**»**Graph Indicators** palette and place it on the front panel. The waveform chart will display the data in real time.
- e. Type Value History inside the label and click outside the label or click the **Enter** button.
- f. The waveform chart legend labels the plot Plot 0. Use the Labeling tool to triple-click Plot 0 in the chart legend, type Value, and click outside the label or click the **Enter** button to relabel the legend.
- g. The random number generator generates numbers between 0 and 1, in a classroom setting you could replace this with a data acquisition VI. Use the Labeling tool to double-click 10.0 in the y-axis, type 1, and click outside the label or click the **Enter** button to rescale the chart.

- h. Change -10.0 in the y-axis to 0.
- i. Label the y-axis Value and the x-axis Time (sec).

Block Diagram

- 3. Select **Window**»Show Diagram to display the block diagram.
- 4. Enclose the two terminals in a While Loop, as shown in the following block diagram.



- a. Select the While Loop on the Functions»Execution Control palette.
- b. Click and drag a selection rectangle around the two terminals.
- c. Use the Positioning tool to resize the loop, if necessary.
- 5. Select the Random Number (0-1) on the **Functions**»Arithmetic and **Comparison**»Numeric palette. Alternatively you could use a VI that is gathering data from an external sensor.
- 6. Wire the block diagram objects as shown in the previous block diagram.
- 7. Save the VI as Use a Loop.vi in your folder
- 8. Display the front panel by clicking it or by selecting Window»Show Panel.
- 9. Run the VI. The section of the block diagram within the While Loop border executes until the specified condition is TRUE. For example, while the STOP button is not pressed, the VI returns a new number and displays it on the waveform chart.
- 10. Click the STOP button to stop the acquisition. The condition is FALSE, and the loop stops executing.
- 11. Format and customize the X and Y scales of the waveform chart.
 - a. Right-click the chart and select **Properties** from the shortcut menu. The following dialog box appears.
 - b. Click the **Scale** tab and select different styles for the y-axis. You also can select different mapping modes, grid options, scaling factors, and formats and precisions. Notice that these will update interactively on the waveform chart
 - c. Select the options you desire and click the **OK** button.

pearance Format	and Precision	Plots	Scales	Documentation
Label		r	Caption —	
Visible			Visibl	le
Waveform Chart				
Enabled State				
 Enabled 				
 Disabled 				
O Disabled & gr	ayed			
Show graph pa	lette		Update r	mode
Show plot leger	nd		Scroll	V
Auto size to	plot names		Stack	plots
1	Plots shown			digital display(s)
Show x scroll b	ar			
Show scale leg	end			
Show cursor le	gend			

12. Right-click the waveform chart and select **Data Operations**»Clear Chart from the shortcut menu to clear the display buffer and reset the waveform chart. If the VI is running, you can select Clear Chart from the shortcut menu.

Adding Timing

When this VI runs, the While Loop executes as quickly as possible. Complete the following steps to take data at certain intervals, such as once every half-second, as shown in the following block diagram.



a. Place the Time Delay Express VI located on the **Functions**»**Execution Control** palette. In the dialog box that appears, insert 0.5. This function would make sure that each iteration occurs every half-second (500 ms).

- b. Divide the millisecond delay by 1000 to get time in seconds. Connect the output of the divide function to the Delay Time (s) input of the Time Delay Express VI. This will allow you to adjust the speed of the execution from the pointer slide on the front panel.
- 13. Save the VI, because you will use this VI later in the course.
- 14. Run the VI.
- 15. Try different values for the millisecond delay and run the VI again. Notice how this effects the speed of the number generation and display.

EXPERIMENT # 3: EXERCISES IN LABVIEW

OBJECTIVE:

The objective of this experiment is to gain familiarity with the various functions of LabView.

INTRODUCTION:

We will conduct the following exercises to gain familiarity with the various functions of LabVIEW. We will need them to develop more advanced VIs in the future.

VI # 4 - ANALYZING AND LOGGING DATA

Complete the following steps to build a VI that measures temperature every 0.25 s for 10s. During the acquisition, the VI displays the measurements in real time on a waveform chart. After the acquisition is complete, the VI plots the data on a graph and calculates the minimum, maximum, and average temperatures. The VI displays the best fit of the temperature graph.

Front Panel

1. Open a new VI and build the following front panel using the following tips.

Current Data	Mean	Max value
100 - 79.46 80 60 40 20 0	0.00	0.00 Min value 0.00
Current Data Point 0		
STOP		

• Do not create the **Mean**, **Max**, and **Min** indicators yet. Create them on the Block Diagram by right clicking on the functions and choosing Create Indicator. Then position them on the Front Panel.

Block Diagram

2. Build the following block diagram.



- a. Select **Functions**»All **Functions**»Select a VI... and choose Thermometer.vi (from previous exercise).
- b. Place the Wait Until Next ms Multiple function located on the Functions»All Functions »Time & Dialog palette and create a constant of 250. Much like the Time Delay Express VI, this function causes the For Loop to execute every 0.25 s (250 ms).
- c. Place the Array Max & Min function located on the **Functions**»All **Functions** »Array palette. This function returns the maximum and minimum temperature.
- d. Place the Mean VI located on the **Functions**»All **Functions**» **Mathematics**»**Probability and Statistics** palette. This VI returns the average of the temperature measurements.
- e. Right-click the output terminals of the Array Max & Min function and Mean VI and select **Create»Indicator** from the shortcut menu to create the **Max**, **Min**, and **Mean** indicators.
- f. Place the Write LabVIEW Measurements File Express VI located on the **Functions**»**Output** palette. LabVIEW will automatically insert the From DDT function into the wire you connect to the Signals input.

3. Save the VI as Temperature Logger.vi.

4. Display the front panel and run the VI.

5. After pressing STOP a dialog box will appear. Enter the name of the file to save the spreadsheet.

6. Open the spreadsheet file to make sure the file was properly created by using Notepad or by creating a VI to read the file as follows.

• Create the following block diagram



- Place the Read LabVIEW Measurement File Express VI located on the **Functions»Input** palette.
- Configure the VI to ask the user to choose the file to read and change the delimiter to Tab
- Right click on the Signals Output and choose create graph indicator

7. Run the VI

VI # 5 - USING WAVEFORM GRAPHS

Front Panel

1. Open a new VI and build the following front panel using the following tips.



- a. Create a waveform graph indicator from the **Controls**»**Graph Indicators** palette. Use the position/size/select tool to move the plot legend to the side, and expand it to display two plots. Use the labeling tool to change the plot names and the properties page to choose different colors for your plots.
- b. Place a Stop button on the front panel.
- c. Place two vertical pointer slides from the **Controls**»**Numeric Controls** palette. Use the properties page again to change the slide fill color.

Block Diagram

3. Build the following block diagram.



- a. Place a While Loop from Functions»Execution Control palette.
- b. Place a **Wait Until Next ms Multiple** from **Functions**»All **Functions** »**Time & Dialog** and create a constant with a value of 100.
- c. Place two Simulate Signal Express VIs from the **Functions**»**Input** and leave the Signal type as Sine for the first Simulate Signal VI and change the Signal Type to Square for the second VI. Wire both of the outputs into the waveform graph. A Merge Signals function will automatically be inserted.
- d. Expand the Simulate Signal Express VIs to show another Input/Output. By default, error out should appear. Change this to Frequency by clicking on error out and choosing **Frequency**.
- 3. Save the VI as Multiplot Graph.vi.
- 4. Display the front panel and run the VI.
- 5. Save and close the VI.

VI # 6 - ERROR CLUSTERS & HANDLING

Front Panel

1. Open a new VI and build the following front panel using the following tips.

Square Root Input	Square Root 0.00
error in (no error)	error out
status code	status code
source	source

- a. Create a numeric control and change the Label to Square Root Input. Create a numeric indicator for Square Root.
- b. Place Error In 3D.ctl from Controls»All Controls»Arrays & Clusters.
- c. Place Error Out 3D.ctl from Controls» All Controls»Arrays & Clusters.

Block Diagram

2. Build the following block diagram.



- a. Place a Case Structure from Functions»Execution Control palette.
- b. Place a **Greater or Equal to 0?** from the **Functions**»**Arithmetic and Comparison**»**Comparison** palette and wire it to the condition terminal of the case structure.

In the True Case:

c. Place the Square Root function from **Functions**»Arithmetic and **Comparison**»Numeric palette.

In the False Case:



- d. Create a numeric constant from **Functions**»Arithmetic and **Comparison**»Numeric palette and type -9999.90.
- e. Place the Bundle By Name from **Functions**»All Functions»Arrays & Clusters palette. Wire from Error in to the center terminal of Bundle by Name to make status show up. Create constants. Wire from the Error Out indicator to the output of Bundle By name.

3. Save the VI as Square Root.vi.

4. Display the front panel and run the VI.

5. Save and close the VI.

EXPERIMENT # 4: DATA ACQUISITION

OBJECTIVE:

The objective of this experiment is acquiring data using NI USB-6009, data acquisition device.

INTRODUCTION:

The NI USB-6009 multifunction I/O is a device that can be used to connect LabVIEW to external devices for Data Acquisition. The NI USB-6009 is a USB based data acquisition (DAQ) and control device with analog input and output and digital input and output.

The main features of NI USB-6009 are as follows:

- Analog input (AI): 8 inputs with referenced single ended signal coupling or 4 inputs with differential signal coupling. Software-configurable voltage ranges: ±20V, ±10V, ±5V, ±4V, ±2.5V, ±2V, ±1.25V, ±1V. Max sampling rate is 48kS/s (48000 samples per second). 14 bits AD converter (USB-6008: 12 bits).
- Analog output (AO): 2 outputs. Voltage range is 0 5V (fixed). Output rate is 150Hz (samples/second). 12 bits DA converter.
- **Digital input (DI) and digital output (DO):** 12 channels which can be used as either DI or DO (configured individually). These 12 channels are organized in ports, with Port 0 having lines 0, ..., 7, and Port 1 having lines 0, ..., 3. Input low is between -0.3V and +0.8V. Input high is between 2.0V and +5.8V. Output low is below 0.8V. Output high is above 2V (with open-drain and push-pull as options).
- Counter: 32 bits: Counting on falling edge.
- **On-board voltage sources** (available at individual terminals): 2.5V and 5.0V
- **Power:** USB-6009 is powered via the USB cable.
- **Configuring and testing:** USB-6009 can be configured and tested using MAX (Measurement and Automation Explorer) 4.0, which is installed with NI-DAQ 8.0.
- Application software: LabVIEW, C, or Visual Studio.
- **Platforms**: Windows, Mac, Linux.

INSTALLING THE DAQ

After inserting the CD, the NI-DAQmx 7.x installer should open automatically. If not, select **Start*Run**. Enter x:\setup.exe, where x is the letter of the CD drive. Complete the instructions in the installer, including rebooting the computer if necessary. For troubleshooting instructions, refer to the Hardware Installation/Configuration Troubleshooter at ni.com/support/install.

Note: Install your driver software *before* installing new hardware devices, so Windows can detect your device.

After installing the software, the actual device should be installed. This is done quite easily by simply plugging in the USB cable into PC and device, and then click **Next** on any dialog that appears. Next click **Finish**.

Note USB-6008/6009 only—If this is the first time that a USB-6008/6009 device is installed on your computer, you might be prompted to install a USB-6*xxx* Firmware Loader. Please complete the Windows Hardware Wizard prompts to completely install this device.

DEVICE CONFIRMATION

Complete the following steps:

- 1. Double-click the **Measurement & Automation** icon on the desktop to open MAX.
- 2. Expand **Devices and Interfaces**, then expand **NI-DAQmx Devices**.

😫 NI USB-6009: "Dev1" - Measureme	ent & Automation Explorer 📃 🗖 🔀
<u>File E</u> dit <u>V</u> iew <u>T</u> ools <u>H</u> elp	
Configuration	Properties X Delete Self-Test X Show Help
⊡ 🔇 My System ⊕ 🕞 Data Neighborhood	Name Value
Devices and Interfaces	Serial Number 0x1195904
NI-DAQmx Devices	
🕘 🛒 P 🔀 Self-Test	
🛨 - PXI P 🔚 Test Panels	
🕀 🕞 Histol 🐪 Reset Device	
in Index Scale	
🕀 🛅 VI Lo, 🍪 Configure TEDS	
🗄 🥸 Remote S Rename 🔀 Delete	Attributes
	Landration
Properties	

3. Check that your device appears under Devices and Interfaces. If your device does not appear, press $\langle F5 \rangle$ to refresh the view in MAX. If the device is still not recognized, refer to ni.com/support/install for troubleshooting information.

4. Right-click your device and select **Self-Test**.

If you need help during the self-test, select **Help**»**HelpTopics**»**NI-DAQmx** and click *Max Help for NI-DAQmx*. When the self-test finishes, a message indicates successful verification or if an error occurred.

You can also use a test panel for testing specific device functionality, such as the ability to acquire and generate signals. It can be done as follows:

1. In MAX, expand Devices and Interfaces»NI-DAQmx Devices.

- 2. Right-click the device to test.
- 3. Select **Test Panels** to open a test panel for the selected device.

Test Panels : USB-9215: "Dev2"	
Analog Input	
Channel Name Dev2/ai0	Max Input Limit Rate (Hz)
Made Continuous	Min Input Limit Samples To Read
Input Configuration Differential	
Ampikude vs. Samples Chart	Auto-scale chart 🕼
9- 2- 0- -2- -4-	\bigcirc
-6-1 0	999 Value 0
Start	
	Help Dose

4. Click **Start** to test different functions of the device. Click **Help** for instructions on operating the test panels.

5. The test panel displays a message indicating whether an error occurred.

To see the terminals of the USB-6009, select **Device Pinouts** in the menu shown below. The terminals or pins are shown in the NI-DAQmx Device Terminals window. The DAQ is now ready to connect external devices to LabVIEW.

💕 NI-DAQmx Device Terminals	
Hide Locate Back Forward Opti	1
Contents Index Search Favorites	NI USB-6009
 ? NI 6731 ? NI 6733 ? NI DAQCard-DIO-24 ? NI PCI-DIO-96 ? NI USB-6008 ? NI USB-6009 ? NI USB-6501 ? NI USB-9201 ? NI USB-9201 DSUB ? NI USB-9211A 	GND 1 17 P0.0 AI 0/AI 0+ 2 18 P0.1 AI 4/AI 0- 3 19 P0.2 GND 4 20 P0.3 AI 1/AI 1+ 5 21 P0.4 AI 5/AI 1- 6 22 P0.5 GND 7 23 P0.6 AI 2/AI 2+ 8 24 P0.7 AI 6/AI 2- 9 25 P1.0 GND 10 26 P1.1 AI 3/AI 3+ 11 27 P1.2
? NI USB-9215A ? NI USB-9215A BNC ? NI USB-9221 ? NI USB-9221 DSUB ? NI USB-9233	Al 37Al 37 Al 7/Al 3- GND AO 0 AO 0 AO 0 AO 0 AO 1 IS 31 GND IS 31 GND IS 31 GND AO 0 AO 1 IS 31 GND IS 32 GND IS 31 GND IS 31 GND IS 32 GND IS 32 GND IS 32 GND IS 32 GND IS 32 GND IS 32 GND IS 32 GND IS 32 GND IS 32 GND IS 32 GND IS 32 GND IS 32 GND IS 32 GND IS 32 GND IS

EXERCISE 1:

Reading a analog signal from a signal generator and displaying in Labview.

The purpose of this exercise is to teach you how to build a LabVIEW application to retrieve voltage input values using the NI USB-6009 data acquisition device.

1. Click "New VI" button to create a new blank LabVIEW program

2. Select Front Panel and enable Controls Palette to choose a "Waveform Chart" indicator in "Graph" group, add to front panel and name it "Voltage".

3. Switch to Block Diagram to verify that a new data terminal was created (named "Voltage").

4. In the Block diagram, open the Functions Palette to get the DAQ Assistant. The path goes as Functions>>Express>>Input>>

DAQ Assistant.

Note: If you have any trouble in finding a

block use the Search function available just below the Title Bar of the Functions Palette.

5. When the DAQ Assistant is placed in the Block diagram window, a window with "Create New..." in the



title bar appears. Select Analog Input and then Voltage.

6. The Physical Tab will appear showing the devices attached and the corresponding pins.
Select the required pin and click Finish.
7. Another DAQ Assistant window will appear.
Under the Voltage Input setup, Settings Tab select the appropriate maximum & minimum input signal range and units.
(preferably, -5 to 5 volts). Also, in the Task Timing Tab under Acquisition mode select 1

Sample (On Demand).Click OK.

	NATIONAL INSTRUMENTS"
	-
🔽 An	alog Input
<u>•</u>	Voltage
	Temperature
*	Strain
•	Current
€]≊	Resistance
R.	Frequency
•	Position
1 💆	Acceleration
🛛 🔗	Custom Voltage with Excitation
0	Sound Pressure
🕨 🕨 An	nalog Output
🕨 🕨 Co	unter Input
Co	unter Output 🛛 🕙
< B	ack Next> Finish Cancel

i ol	nysical	
_	orted Physical Channels	
B	Dev1 (USB-6009)	
	aiO	
	ai1	
	ai2	
	ai3	
	ai4	
	ai5	
	ai6	
	ai7	

Voltage	age Input Setup Settings Signal Input Range Max 5 Scaled Units Min -5 Volts V	Back Measuring Voltage Most measurement devices are designed for measuring, or reading, voltage. Two
Click the Add Channels button to add more channels to the task.	Terminal Configuration Differential Custom Scaling <no scale=""> V</no>	common <u>voltage</u> <u>measurements</u> are D and AC. DC voltages are usefu for measuring phenomena that change slowly with time, such as temperature, pressur or strain. AC voltages, on the other hand, are waveforms that constantly increase, decrease, and revers polarity. Most powerlines deliver AC voltage.
 1 Sample (On Demand) 1 Sample (HW Timed) N Samples 	Clock Settings Samples To Read 1000	
Continuous Advanced Clock Settings Clock Type Active Edge Internal Rising V	Clock Source	This is the list of virt channels. Right-dick virtual channel to rename it, change th physical channel associated with it, or
φ Express Task 🎉 Connection Diagram		remove it from the lin If an asterisk appear next to a global virtu channel, the channel has unsaved change:

8. Connect the data output from the DAQ Assistant to the Waveform chart terminal, using the wiring tool. If the wiring tool does not appear automatically on moving the cursor over the Data output of DAQ, go to View>>Tools Palette and select the wiring tool. To make wiring easier, you can invoke the Help window to support it. The Help window shows input and output parameters of each selected VI. (The way to display the Help window is to click on the Help menu selection and select the "Show Context Help" option)

9. You can change the window to the Front Panel window and click the "Run" (or "Run Continuously") button to execute the VI.

10. If your waveform chart does not show the whole graph, you can change the scale of the Yaxis. To change the Y axis scale on the waveform chart, move the cursor to the graphic origin, click the left mouse button, and type in the desired value

11. The "Run Continuously" button executes the VI continuously. You can also add a "While Loop" to enhance your program. First, move mouse to the Block Diagram. Open the Functions Palette and select the Structures group and then the While Loop. Add the While Loop to the Block Diagram and enlarge it to include the DAQ Assistant and the Voltage Waveform data terminal. On the front panel add a Stop button (from

Controls>>Boolean>>Stop Button) to control the execution of the While Loop. In the block diagram, wire the stop button of the front panel to the stop button of the while loop. 12. After wiring, switch to Front Panel and press the RUN button to execute the VI.



EXERCISE 2:

Sending an analog signal from the NI USB 6009 and displaying in a Oscilloscope.

The purpose of this exercise is to teach you how to build a LabVIEW application to send voltage outputs values from NI USB 6009 data acquisition cards.

1. Click "New VI" button to create a new blank LabVIEW program

2. Select Front Panel and enable Controls Palette to choose a "Waveform Chart" indicator in "Graph" group, add to front panel and name it "Voltage".

3. Switch to Block Diagram to verify that a new data terminal was created (named "Voltage").

4. In the Block diagram, open the Functions Palette to get the DAQ Assistant. The path goes as Functions>>Express>>Input>> DAQ Assistant.

Note: If you have any trouble in finding a block use the Search function available just below the Title Bar of the Functions Palette.

5. When the DAQ Assistant is placed in the Block diagram window, a window with "Create New…" in the title bar appears. Select Analog Output and then Voltage.

6. The Physical Tab will appear showing the devices attached and the corresponding pins. Select the required pin and click Finish.

7. Another DAQ Assistant window will appear. Under the Voltage Output setup, Settings Tab select the appropriate maximum & minimum input signal range and units.(preferably, 0 to 10 volts). Also, in the Task Timing Tab under Acquisition mode select 1 Sample (On Demand).Click OK.

7. Generate a sinusoidal signal using the express VI using the "Simulate sig" express VI. The path to access these "Functions" >> Express>> "Inputs" >> "Simulate sig".

Select a type of signal, its amplitude and frequency. Select a number of "samples per second" as 1000 and uncheck the automatic for number of samples and select "1" as number of samples. Now connect the output of "Simulate sig" to the voltage input of the DAQ Assistant.

8. Also connect the Voltage waveform to the output of "Simulate sig".

9. Complete your wiring and run to see the result in your graph as well as the oscilloscope.

10. The "Run Continuously" button executes the VI continuously. You can also add a "While Loop" to enhance your program. First, move mouse to the Block Diagram. Open the Functions Palette and select the Structures group and then the While Loop. Add the While Loop to the Block Diagram and enlarge it to include the DAQ Assistant and the Voltage Waveform data terminal. On the front panel add a Stop button (from Controls>>Boolean>>Stop Button) to control the execution of the While Loop. In the block diagram, wire the stop button of the front panel to the stop button of the while loop. 12. After wiring, switch to Front Panel and press the RUN button to execute the VI.

Make sure that all your external wiring is connected properly and all devices have a common ground.

EXPERIMENT # 5: SENDING AN ANALOG OUTPUT

OBJECTIVE:

The objective of this experiment is to send an analog signal from NI USB-6009 and displaying in the oscilloscope.

INTRODUCTION:

An analog or analogue <u>signal</u> is any variable signal <u>continuous</u> in both time and amplitude. It differs from a <u>digital signal</u> in that small fluctuations in the signal are meaningful. Analog is usually thought of in an <u>electrical</u> context, however <u>mechanical</u>, <u>pneumatic</u>, <u>hydraulic</u>, and other systems may also convey analog signals.

An analog signal uses some property of the medium to convey the signal's information. For example, an <u>aneroid barometer</u> uses rotary position as the signal to convey pressure information. Electrically, the property most commonly used is <u>voltage</u> followed closely by <u>frequency</u>, <u>current</u>, and <u>charge</u>. Any information may be conveyed by an analog signal, often such a signal is a measured <u>response</u> to changes in physical phenomena, such as <u>sound</u>, <u>light</u>, <u>temperature</u>, <u>position</u>, or <u>pressure</u>, and is achieved using a <u>transducer</u>. For example, in an analog sound recording, the variation in <u>pressure</u> of a <u>sound</u> striking a microphone creates a corresponding variation in the voltage, amplitude of a current passing through it. An increase in the volume of the sound causes the fluctuation of the current's voltage amplitude to increase while keeping the same rhythm.

EXERCISE:

SENDING AN ANALOG SIGNAL FROM THE NI USB 6009 AND DISPLAYING IN A OSCILLOSCOPE

The purpose of this exercise is to teach you how to build a LabVIEW application to send voltage outputs values from NI USB 6009 data acquisition cards.

1. Click "New VI" button to create a new blank LabVIEW program

2. Select Front Panel and enable Controls Palette to choose a "Waveform Chart" indicator in "Graph" group, add to front panel and name it "Voltage".

3. Switch to Block Diagram to verify that a new data terminal was created (named "Voltage").

4. In the Block diagram, open the Functions Palette to get the DAQ Assistant. The path goes as Functions>>Express>>Input>> DAQ Assistant.

Note: If you have any trouble in finding a block, use the Search function available just below the Title Bar of the Functions Palette.

5. When the DAQ Assistant is placed in the Block diagram window, a window with "Create New…" in the title bar appears. Select Analog Output and then Voltage.

6. The Physical Tab will appear showing the devices attached and the corresponding pins. Select the required pin and click Finish.

7. Another DAQ Assistant window will appear. Under the Voltage Output setup, Settings Tab select the appropriate maximum & minimum input signal range and units.(preferably, 0 to 10 volts). Also, in the Task Timing Tab under Acquisition mode select 1 Sample (On Demand).Click OK.

7. Generate a sinusoidal signal using the express VI using the "Simulate sig" express VI. The path to access these "Functions" >> Express>> "Inputs" >> "Simulate sig". Select a type of signal, its amplitude and frequency. Select a number of "samples per second" as 1000 and uncheck the automatic for number of samples and select "1" as number of samples. Now connect the output of "Simulate sig" to the voltage input of the DAQ Assistant.

8. Also connect the Voltage waveform to the output of "Simulate sig".

9. Complete your wiring and run to see the result in your graph as well as the oscilloscope.

10. The "Run Continuously" button executes the VI continuously. You can also add a "While Loop" to enhance your program. First, move mouse to the Block Diagram. Open the Functions Palette and select the Structures group and then the While Loop. Add the While Loop to the Block Diagram and enlarge it to include the DAQ Assistant and the Voltage Waveform data terminal. On the front panel add a Stop button (from Controls>>Boolean>>Stop Button) to control the execution of the While Loop. In the block diagram, wire the stop button of the front panel to the stop button of the while loop. 12. After wiring, switch to Front Panel and press the RUN button to execute the VI.

Make sure that all your external wiring is connected properly and all devices have a common ground.

EXPERIMENT # 6: DIGITAL INPUT / OUTPUT

OBJECTIVE:

The objective of this experiment is to send and receive digital values using NI USB 6009 data acquisition cards.

INTRODUCTION:

Digital signals are digital representations of <u>discrete-time signals</u>, which are often derived from <u>analog signals</u>. An analog signal is a datum that changes over time—say, the temperature at a given location; the depth of a certain point in a pond; or the amplitude of the voltage at some node in a circuit—that can be represented as a mathematical function, with time as the free variable (abscissa) and the signal itself as the dependent variable (ordinate). A discrete-time signal is a sampled version of an analog signal: the value of the datum is noted at fixed intervals (for example, every microsecond) rather than continuously.

If individual time values of the discrete-time signal, instead of being measured precisely (which would require an infinite number of digits), are approximated to a certain precision—which, therefore, only requires a specific number of digits—then the resultant data stream is termed a digital signal. The process of approximating the precise value within a fixed number of digits, or bits, is called <u>quantization</u>. In conceptual summary, a digital signal is a quantized discrete-time signal; a discrete-time signal is a sampled analog signal.

In most applications, digital signals are represented as <u>binary numbers</u>, so their precision of quantization is measured in <u>bits</u>. Suppose, for example, that we wish to measure a signal to two significant decimal digits. Since seven bits, or binary digits, can record 128 discrete values (*viz.*, from 0 to 127), those seven bits are more than sufficient to express a range of one hundred values.

EXERCISE:

SENDING AND RECEIVING DIGITAL SIGNALS

The purpose of this exercise is to teach you how to build a LabVIEW application to send and receive digital values from NI USB 6009 data acquisition cards.

1. Click "New VI" button to create a new blank LabVIEW program

2. Select Front Panel and enable Controls Palette to choose a "Push Button" indicator in "Boolean" group (you can also use a toggle or slide switch, etc. as well), add to front panel and name it "Status".

3. Switch to Block Diagram to verify that a new data terminal was created (named "Status").

4. In the Block diagram, open the Functions Palette to get the DAQ Assistant. The path goes as Functions>>Express>>Input>> DAQ Assistant.

Note: If you have any trouble in finding a block use the Search function available just below the Title Bar of the Functions Palette.

5. When the DAQ Assistant is placed in the Block diagram window, a window with "Create New…" in the title bar appears. Select Digital I/O and then Line Output.

6. The Physical Tab will appear showing the devices attached and the corresponding pins. Select the required pin(s) and click Finish.

7. Another DAQ Assistant window will appear. Under the Task Timing Tab under Acquisition mode select 1 Sample (On Demand).Click OK.

7. If you want to send more than 1 signal at a time, then first put more Boolean switches/buttons on the front panel. In the Block diagram, connect all the Boolean terminals into one using "Functions" >> Programming>> "Arrays" >> "Build arrays". Extend the size of the array according to the number of signals to send.

8. Next connect the array output to the data pin of the DAQ assistant.

Note: Make sure that the correct pin numbers are assigned to the Boolean switches in the DAQ Assistant.

9. You can also add LEDs (from Controls>>Boolean) and connect them to the switches in the block diagram if you want to view the result on the front panel as well.

10. The "Run Continuously" button executes the VI continuously. You can also add a "While Loop" to enhance your program. First, move mouse to the Block Diagram. Open the Functions Palette and select the Structures group and then the While Loop. Add the While Loop to the Block Diagram and enlarge it to include the DAQ Assistant and the Voltage Waveform data terminal. On the front panel add a Stop button (from Controls>>Boolean>>Stop Button) to control the execution of the While Loop. In the block diagram, wire the stop button of the front panel to the stop button of the while loop. 12. After wiring, switch to Front Panel and press the RUN button to execute the VI.

13. For testing Digital input, Select Digital I/O>>Line Input in the DAQ assistant and instead of Boolean switches use LEDs. Also Index array can be used.

Note: In hard wire, real LEDs and switches can be used for demonstration. Make sure that all your external wiring is connected properly and all devices have a common ground.

Boolean	Boolean 2	Boolean 3	Boolean 4
Boolean 5	Boolean 6	Boolean 7	Boolean 8
	STOP		


EXPERIMENT # 7: ON-OFF CONTROL

OBJECTIVE:

The objective of this experiment is to implement ON/OFF Control.

INTRODUCTION:

In this experiment we will implement a simple control strategy, namely On-Off Control. This strategy is based on a simple condition by which the maximum control signal is given if the output has not reached the desired set point. When the output reaches the desired value a zero control signal is sent to the plant.

To conduct this experiment, we will have to first connect the 2-Tank system to LabVIEW through the NI DAQ card. The steps are as follows:

- 1. Connect the sensor of the tank system (top-most pin) to any Analog Input (AI) pin of the DAQ card.
- 2. Next connect the motor $(2^{nd} \text{ last/above ground})$ to an Analog Output (AO) pin.
- 3. Connect the ground of the tank (bottom most) pin to a ground of the DAQ.

Now the hard wire connections are complete and we can start building the VI.

To build the VI follow the following steps:

1. Click "New VI" button to create a new blank LabVIEW program

2. Select Front Panel and enable Controls Palette to choose a "Waveform Chart" icon in the "Graph" group, add to front panel and name it "Level".

3. Switch to Block Diagram to verify that a new data terminal was created (named "Level").

4. In the Block diagram, go to **"Functions"** >> **Programming**>> **"Structures"** >> **"Flat Sequence"** and place it in the window. Next add 4 frames to it by right clicking on the border of the frame and selecting Add Frame After (or Before).

5. In the first frame go to "Functions" >> Programming>> "Timing" >> "Wait Until Next ms Multiple" and place the icon in the frame. Then go to "Functions" >> Programming>> "Numeric" >> "Numeric Constant" in the frame and enter the value 100 in it. Wire it to the timing icon. This will set the sampling time to 100ms.

6. In the next frame, open the Functions Palette to get the DAQ Assistant. The path goes as Functions>>Express>>Input>> DAQ Assistant.

Note: If you have any trouble in finding a block use the Search function available just below the Title Bar of the Functions Palette.

7. When the DAQ Assistant is placed in the Block diagram window, a window with "Create New…" in the title bar appears. Select Analog Input and then Voltage.

8. The Physical Tab will appear showing the devices attached and the corresponding pins. Select the required pin (plant sensor) and click Finish.

9. Another DAQ Assistant window will appear. Under the Voltage Input setup, Settings Tab select the appropriate maximum & minimum input signal range and

units.(preferably, 0 to 10 volts). Also, in the Task Timing Tab under Acquisition mode select 1 Sample (On Demand).Click OK.

10. Wire the data pin of the DAQ Assistant i.e. sensor output to the waveform chart (Level).

Note: You can also add a Tank indicator on the front panel by going to Controls>> Modern>>Numeric>>Tank. But for this you will have to properly scale the tank in order to give you accurate readings. For this multiply the sensor reading by 25 and add a constant to it before sending it to the tank and on the front panel manually change the maximum tank reading to 250. (Method of scaling can be different also.)

11. In the third frame, go to "Functions" >> Programming>> "Comparison" >> "Greater Or Equal?" and place the icon. Connect the top pin (x) of the icon to the sensor output from DAQ Assistant and connect the bottom pin (y) to a numeric constant-from the Numeric Palette. Enter your set point as this constant.

12. Go to **"Functions"** >> **Programming**>> **"Structures"** >> **"Case Structure"** and place it in the frame. Connect the Case selector i.e. the question mark on the left border of the Case Structure to the output of the Comparison Icon.

13. In the True window of the Case structure place another DAQ Assistant similar to the first one, except that this should be an Analog Output. Send the value of 0 to the Data pin by using the numeric constant function. Similarly, in the false window, send a value of 5 to the DAQ Assistant. (You can copy-paste it from the True window.)

14. The "Run Continuously" button executes the VI continuously. You can also add a "While Loop" to enhance your program. First, move mouse to the Block Diagram. Open the Functions Palette and select the Structures group and then the While Loop. Add the While Loop to the Block Diagram and enlarge it to include the whole sequence. On the front panel add a Stop button (from Controls>>Boolean>>Stop Button) to control the execution of the While Loop.

14. In the last frame place the Stop button terminal and connect it to the stop button of the while loop.

15. To make sure that the motor is turned off when the program is terminated, add another case structure in the last frame and connect the Case Selector (question mark on the left border of the Case Structure) to the Stop button. In the True window of the Case structure place a DAQ Assistant similar to the one in the previous frame (Analog Output). Next, send the value of 0 to its Data pin by using the numeric constant function.

16. In the 2-Tank system open the exit valve a little to see the proper effect of On-Off Control. The valve can be opened to the number 2 position or another one depending on the speed of the motor.

17. After wiring, switch to Front Panel and press the RUN button to execute the VI.





EXPERIMENT # 8: ON-OFF CONTROL WITH DEAD ZONE

OBJECTIVE:

The objective of this experiment is to implement ON/OFF Control with dead zone.

INTRODUCTION:

This experiment is similar to the previous one with the exception that instead of having one fixed set-point value, it will have a fixed **"Range"** determined by 2 values i.e. the Upper and Lower limits. This is done since constant switching On and Off of the motor can be damaging and so the frequency of switching must be reduced.

Another difference in this experiment is that we will be using an "Instrumentation Amplifier"- the **EI-1040 Dual Programmable Gain Instrumentation Amplifier**. This is because the NI DAQ card gives a maximum voltage of 5V whereas the Tank system can take up to 10V. So, we will amplify the signal from the DAQ (by a factor of 10) before sending it to the Tank. The pin configuration of the Amplifier is as follows:

LABEL	DESCRIPTION	LABEL	DESCRIPTION
GND In	POWER SOURCE GROUND	GND	SIGNAL GROUND
+5 In	5 VOLT FROM POWER SOURCE	-15V OUT	-15 VOLT USER AT 8 ma *
+5 In	SPARE 5 VOLT TERMINAL	+15V OUT	+15 VOLT USER AT 8 ma *
GSB2	GAIN STATE B2	EXCT	4.096 VOLT FOR EXCITATION **
GSB1	GAIN STATE B1	B- In	B AMP MINUS INPUT
GSA2	GAIN STATE A2	B+ In	B AMP PLUS INPUT
GSA1	GAIN STATE A1	GND	SIGNAL GROUND
B Out	B AMPLIFIER OUTPUT	A- In	A AMP MINUS INPUT
A Out	A AMPLIFIER OUTPUT	A+ In	A AMP PLUS INPUT

* Worst case current availability - actual current availability may be greater ** Current availability is 3 ma max

The Amplifier needs a 5V power supply and its gain can be set using the Gain State pins. Combinations of gain can be selected so that for example one amplifier can have a gain of 10 and the other have a gain of 100. The different gains are 1, 10, 100, and 1000 and can be set through the following

	0	U
GAIN	TERMINAL	TERMINAL
	GSA1 or B1	GSA2 or B2
1	0	0
10	1	0
100	0	1
1000	1	1



combinations:

The voltage level of a 0 is typically ground and the level of a 1 is 2 volts above the digital ground.

To conduct the experiment, we will have to first connect the 2-Tank system to LabVIEW through the NI DAQ card and Amplifier set up. The steps are as follows:

- 4. Connect the sensor of the tank system (top-most pin) to any Analog Input (AI) pin of the DAQ card.
- 5. Connect the +5 In and GND In pins of the Amplifier to the 5V and ground terminals of the Power supply.
- 6. Connect the negative input of the amplifier you are using, A- In or B- In, to ground and connect the positive inputs, A+ In or B+ In, to an Analog Output (AO) pin of the DAQ.
- 7. Next connect the motor (2nd last/above ground) to the Amplifier Output i.e. A Out or B Out.
- 8. Connect the ground of the Amplifier to the ground of the DAQ.
- 9. Connect the ground of the tank (bottom most) pin to a ground of the DAQ.

Note: Make sure that ALL devices are connected to a common ground. Now the hard wire connections are complete and we can start building the VI.

To build the VI follow the following steps:

1. Click "New VI" button to create a new blank LabVIEW program

2. Select Front Panel and enable Controls Palette to choose a "Waveform Chart" icon in the "Graph" group, add to front panel and name it "Level".

3. Switch to Block Diagram to verify that a new data terminal was created (named "Level").

4. In the Block diagram, go to **"Functions"** >> **Programming**>> **"Structures"** >> **"Flat Sequence"** and place it in the window. Next add 4 frames to it by right clicking on the border of the frame and selecting Add Frame After (or Before).

5. In the first frame go to "Functions" >> Programming>> "Timing" >> "Wait Until Next ms Multiple" and place the icon in the frame. Then go to "Functions" >> Programming>> "Numeric" >> "Numeric Constant" in the frame and enter the value 100 in it. Wire it to the timing icon. This will set the sampling time to 100ms.

6. In the next frame, open the Functions Palette to get the DAQ Assistant. The path goes as Functions>>Express>>Input>> DAQ Assistant.

Note: If you have any trouble in finding a block use the Search function available just below the Title Bar of the Functions Palette.

7. When the DAQ Assistant is placed in the Block diagram window, a window with "Create New…" in the title bar appears. Select Analog Input and then Voltage.

8. The Physical Tab will appear showing the devices attached and the corresponding pins. Select the required pin (plant sensor) and click Finish.

9. Another DAQ Assistant window will appear. Under the Voltage Input setup, Settings Tab select the appropriate maximum & minimum input signal range and units (preferably, 0 to 10 volts). Also, in the Task Timing Tab under Acquisition mode select 1 Sample (On Demand).Click OK.

10. Wire the data pin of the DAQ Assistant i.e. sensor output to the waveform chart (Level).

Note: You can also add a Tank indicator on the front panel by going to Controls>> Modern>>Numeric>>Tank. But for this you will have to properly scale the tank in order to give you accurate readings. For this multiply the sensor reading by 25 and add a constant to it before sending it to the tank and on the front panel manually change the maximum tank reading to 250. (Method of scaling can be different also.)

11. In the third frame, go to "Functions" >> Programming>> "Comparison" >> "Greater Or Equal?" (or "Less Or Equal?") and place the icon. Connect the top pin (x) of the icon to the sensor output from DAQ Assistant and connect the bottom pin (y) to a numeric constant-from the Numeric Palette. Enter your Upper (or Lower) limit as this constant.

Note: You can also place "Vertical Pointer Slides" on the Front Panel from Controls>>Modern>>Numeric and use them to set the Upper/Lower limits.

12. Go to **"Functions"** >> **Programming**>> **"Structures"** >> **"Case Structure"** and place it in the frame. Connect the Case selector i.e. the question mark on the left border of the Case Structure to the output of the Comparison Icon.

13. In the True window of the Case structure place another DAQ Assistant similar to the first one, except that this should be an Analog Output. Send the value of 0 to the Data pin by using the numeric constant function.

14. In the false window, place another Case structure. Place the "Less Or Equal?" icon outside the structure and connect its output to the Case Selector (question mark). Connect the top pin (x) of the icon to the sensor output from DAQ Assistant and connect the bottom pin (y) to a numeric constant-from the Numeric Palette. Enter your Lower (or Upper) limit as this constant.

Note: You can use Vertical Pointer Slides as well.

15. In the True window of the inner structure place another similar DAQ Assistant (Analog Output). Send the value of 1 (it will be later amplified to 10V) to the Data pin by using the numeric constant function. Leave the other window blank.

16. In the 2-Tank system open the exit valve a little to see the proper effect of On-Off Control. The valve can be opened to the number 2 position or another one depending on the speed of the motor.

17. In the Front Panel enable Controls Palette to choose a "Push Button" indicator in "Boolean" group (you can also use a toggle or slide switch, etc. as well), add 2 of them and name them "GSA1" and "GSA2". In the Block Diagram (3rd frame), connect all the Boolean terminals into one using "Functions" >> Programming>> "Arrays" >> "Build arrays". Place a DAQ Assistant and select Digital I/O and then Line Output. Select the required pins, select 1 Sample (On Demand) and click OK.

Finally connect the array output to the data pin of the DAQ assistant.

Note: Make sure that the correct pin numbers are assigned to the Boolean switches in the DAQ Assistant.

18. The "Run Continuously" button executes the VI continuously. You can also add a "While Loop" to enhance your program. First, move mouse to the Block Diagram. Open the Functions Palette and select the Structures group and then the While Loop. Add the While Loop to the Block Diagram and enlarge it to include the whole sequence. On the

front panel add a Stop button (from Controls>>Boolean>>Stop Button) to control the execution of the While Loop.

19. In the last frame place the Stop button terminal and connect it to the stop button of the while loop.

20. To make sure that the motor is turned off when the program is terminated, add another case structure in the last frame and connect the Case Selector (question mark on the left border of the Case Structure) to the Stop button. In the True window of the Case structure place a DAQ Assistant similar to the one in the previous frame (Analog Output). Next, send the value of 0 to its Data pin by using the numeric constant function.

21. After wiring, switch to Front Panel and press the RUN button to execute the VI.





EXPERIMENT # 9: PROPOTIONAL CONTROL

OBJECTIVE:

The objective of this experiment is to implement Proportional Control

INTRODUCTION:

Proportional Controller (part of the PID controller) is a common <u>feedback loop</u> component in industrial <u>control systems</u>. The controller takes a measured value from a <u>process</u> or other apparatus and compares it with a reference <u>setpoint</u> value. The difference (or "error" signal) is then used to adjust some input to the process in order to bring the process' measured value back to its desired setpoint. Basically, when the controller reads a sensor, it subtracts this measurement from the "setpoint" to determine the "error". It then uses the error to calculate a correction to the process's output measurement.

It is used mainly to handle the immediate error, which is multiplied by a constant P (for "proportional"), and added to the controlled quantity. P is only valid in the band over which a controller's output is proportional to the error of the system. This is known as the Propotional Band, often abbreviated as P_b . A controller setting of 100% proportional band means that a 100% change of the error signal (setpoint – process variable) will result in 100% change of the output, which is a gain of 1.0. A 20% proportional band indicates that 20% change in error gives a 100% output change, which is a gain of 5.

$$P_b = 100/gain \quad OR \quad K_p = \frac{1}{P_b}$$

With proportional band, the controller output is proportional to the error or a change in measurement (depending on the controller). So,

(controller output) = (error)*100/(proportional band)

This theory will be implemented on the 2-Tank system in this experiment. The controller will be designed in a VI while the hardware connections remain the same- as shown below:

- 10. Connect the sensor of the tank system (top-most pin) to any Analog Input (AI) pin of the DAQ card.
- 11. Connect the +5 In and GND In pins of the Amplifier to the 5V and ground terminals of the Power supply.
- 12. Connect the negative input of the amplifier you are using, A- In or B- In, to ground and connect the positive inputs, A+ In or B+ In, to an Analog Output (AO) pin of the DAQ.

- 13. Next connect the motor (2nd last/above ground) to the Amplifier Output i.e. A Out or B Out.
- 14. Connect the ground of the Amplifier to the ground of the DAQ.
- 15. Connect the ground of the tank (bottom most) pin to a ground of the DAQ.

Note: Make sure that ALL devices are connected to a common ground.

The VI will be build as follows:

1. Click "New VI" button to create a new blank LabVIEW program.

2. In the Block diagram, go to **"Functions"** >> **Programming**>> **"Structures"** >> **"Flat Sequence"** and place it in the window. Next add 4 frames to it by right clicking on the border of the frame and selecting Add Frame After (or Before).

3. Keep the 1st two frames and the last frame the same as they were for On-Off Control viz.

- The 1st frame to set the sampling time to 100ms- using **Wait Until Next ms Multiple** and **Numeric Constant**.
- The 2nd frame to receive the sensor signal from the Tank, scale it properly and display it on the front panel in a graph as well as tank format- using **DAQ** Assistant, Waveform Chart, Tank and other numeric icons.
- The last frame to manually terminate the execution of the program through a stop button on the front panel and make sure the motor is turned off at the end- using **DAQ Assistant**, **Case Structure** and **Numeric Constant**. (The entire Flat Sequence must be included in the while loop and the Stop

button terminal must be connected to the stop button of the while loop) 4. Calculate the Error by subtracting ("Functions" >> Programming>> "Numeric" >> "Subtract") the sensor value or level from the desired set point. The set point can be given in the form of a Numeric Constant in the Block diagram or through Vertical pointer slides, Numeric controls, etc. on the Front panel. This can be done in the 2nd or 3rd frame. 5. On the front panel, add a Control Knob from the Numeric palette. This will be used to control the Proportional gain K_p . In the 3rd frame of the Block diagram sequence, multiply the error with the gain- connect the error and gain terminal to a multiplication block.

6. In the same frame check the above product (input to controller) and if it is greater than 1 send one to the Tank system- using DAQ. If it is lesser than 0 send the tank 0. If it is between 0 and 1, send the control input as it is. The comparison can be done using "Greater Or Equal?" and "Lesser Or Equal?" functions along with a Case Structure having another Case Structure inside (as in the On-Off Control). Here the control input is connected to the Case Selector.

7. After all the wiring is complete switch to Front Panel and press the RUN button to execute the VI.





EXPERIMENT # 10: PI CONTROLLER

OBJECTIVE:

The objective of this experiment is to implement PI Controller.

INTRODUCTION:

The next step in PID control is the inclusion of the **Integral** component – It is needed to learn from the past. The error is integrated (added up) over a period of time, and then multiplied by a constant K_i (making an average), and added to the controlled quantity. A simple proportional system either oscillates, moving back and forth around the setpoint because there's nothing to remove the error when it overshoots, or oscillates and/or stabilizes at a too low or too high value. By adding a proportion of the average error to the process input, the average difference between the process output and the setpoint is continually reduced. Therefore, eventually, a well-tuned PID loop's process output will settle down at the setpoint. As an example, a system that has a tendency for a lower value (heater in a cold environment), a simple proportional system would oscillate and/or stabilize at a too low value because when zero error is reached P is also zero thereby halting the system until it again is too low. Larger K_i implies steady state errors are eliminated quicker. The tradeoff is larger overshoot: any negative error integrated during transient response must be integrated away by positive error before we reach steady state. The integral component is always used with the proportional one and is so referred to as PI controller.

This theory will be implemented on the 2-Tank system in this experiment. The controller will be designed in a VI while the hardware connections remain the same- as shown below:

- 16. Connect the sensor of the tank system (top-most pin) to any Analog Input (AI) pin of the DAQ card.
- 17. Connect the +5 In and GND In pins of the Amplifier to the 5V and ground terminals of the Power supply.
- 18. Connect the negative input of the amplifier you are using, A- In or B- In, to ground and connect the positive inputs, A+ In or B+ In, to an Analog Output (AO) pin of the DAQ.
- 19. Next connect the motor (2nd last/above ground) to the Amplifier Output i.e. A Out or B Out.
- 20. Connect the ground of the Amplifier to the ground of the DAQ.
- 21. Connect the ground of the tank (bottom most) pin to a ground of the DAQ.

Note: Make sure that ALL devices are connected to a common ground. The VI will be build as follows:

1. Click "New VI" button to create a new blank LabVIEW program.

2. In the Block diagram, go to **"Functions"** >> **Programming**>> **"Structures"** >> **"Flat Sequence"** and place it in the window. Next add 4 frames to it by right clicking on the border of the frame and selecting Add Frame After (or Before).

3. Keep the 1st two frames and the last frame the same as they were for On-Off Control viz.

- The 1st frame to set the sampling time to 100ms- using **Wait Until Next ms Multiple** and **Numeric Constant**.
- The 2nd frame to receive the sensor signal from the Tank, scale it properly and display it on the front panel in a graph as well as tank format- using **DAQ Assistant, Waveform Chart, Tank** and other numeric icons.
- The last frame to manually terminate the execution of the program through a stop button on the front panel and make sure the motor is turned off at the end- using **DAQ Assistant**, **Case Structure** and **Numeric Constant**. (The entire Flat Sequence must be included in the while loop and the Stop button terminal must be connected to the stop button of the while loop)

4. Calculate the Error by subtracting (**"Functions"** >> **Programming**>> **"Numeric"** >> **"Subtract"**) the sensor value or level from the desired set point. The set point can be given in the form of a Numeric Constant in the Block diagram or through Vertical pointer slides, Numeric controls, etc. on the Front panel. This can be done in the 2^{nd} or 3^{rd} frame. 5. On the front panel, add 2 Control Knobs from the Numeric palette. This will be used to control the Proportional gain K_p and the Integral Gain K_L .

6. In the 3rd frame of the Block diagram sequence, check if the error is less than zero. If it is, then send the tank 0.If not go to the next step. The comparison can be made using the Case Structure and the "Lesser Or Equal?" function.

7. Multiply the error with the gain by connecting the error and gain terminal to a multiplication block. Also, integrate the error by sending it to the Integral block ("Functions" >> Mathematics>> Integ & diff >> Time Domain Math- select Integral in this block) and then multiply the integrated error with the Integral gain as was done with the Proportional gain. Next, add the 2 products together (use compound arithmetic or 2 add functions). Send the sum to the Tank through the DAQ Assistant.

8. In the same frame check the above product (input to controller) and if it is greater than 1 send one to the Tank system- using DAQ. If it is lesser than 0 send the tank 0. If it is between 0 and 1, send the control input as it is. The comparison can be done using "Greater Or Equal?" and "Lesser Or Equal?" functions along with a Case Structure having another Case Structure inside (as in the On-Off Control). Here the control input is connected to the Case Selector.

9. In the 2-Tank system open the exit valve a little to see the proper effect of the PI Control. The valve can be opened to the number 2 position or another one depending on the speed of the motor.

10. After all the wiring is complete switch to Front Panel and press the RUN button to execute the VI.